

Report

Function test pressure type leak detector

Site of facility

Company

First name / last name

Street

Postcode / city

Product ☐ Europress LAD-10 Approval: Z-65.23-3

☐ Europress Approval: Z-65.23-3 or CE or ÜHP

Serial number

Measurement Measurements of the switching points yielded the following results:

Alarm on: _____ mbar Pump on: _____ mbar

Alarm off: _____ mbar Pump off: _____ mbar

- Checklist**
- ☐ Results of visual inspection of the system: Installation as per instructions, no visible damage.
 - ☐ When the pressure dropped below the alarm threshold, the device triggered visual and audible alarms.
 - ☐ When the Test key was pressed, the device triggered visual and audible alarms.
 - ☐ The audible alarm can be acknowledged.
 - ☐ The operation and alarm lamps function properly.
 - ☐ The drying beads in the drying filter have been replaced when completely discoloured or they are still usable.

Date of test:

**Specialised
company
(as per WHG
(AwSV)):**

Company

First name / last name

Street

Postcode / city

Signature/stamp