

Report Function test protection equipment against siphoning

Site of facility

Company _____

First name / last name _____

Street _____

Postcode / city _____

- Product**
- KAV, piston type anti-siphon valve approval: Z-65.50-415
 - MAV, diaphragm type anti-siphon valve approval: Z-65.50-415
 - Diaphragm valve against siphoning approval: _____

Measurement The function test was performed by means of the anti-siphon valve tester:

Measurement result: _____ bar

Siphoning protection **works**

Siphoning protection **does not work**

Measurement alternative: Test

- The function test was not performed. A test by simulation of a line leak was performed by opening at the lowest point of the oil line. No significant amount of oil escaped.
- KAV only: The adjustment value was adapted to the current level in the tank prior to the test and reset to the maximum possible level after the test.**

Checklist

- Results of visual inspection: Installation as per instructions, no visible damage.
- The adjustment height was tested and lead-sealed.
- The fuel oil consumer was started to de-aerate the fuel line and then stopped.

Adjustment value Adjustment value for safe height: _____

Notes

Date of test: _____

Specialised company (as per WHG (AwSV)):

Company _____

First name / last name _____

Street _____

Postcode / city _____

Signature/stamp _____